

REQUEST FOR PROPOSALS (RFP), AC AND COIL REPLACEMENT HILLSIDE HEIGHTS

REQUEST FOR PROPOSALS:

AC and Coil Replacement Hillside Heights

The Moline Housing Authority is soliciting proposals from qualified and experienced companies for the replacement of the Carrier 30 ton condensing unit and coil in existing air handler.

Scope of Work:

The bidder to furnish labor, materials, tools, supervision, and install / remove the following: Remove old condensing unit from roof and coil from existing air handler. Install new Carrier 30 ton condensing unit and matching coil in penthouse. Pressure test existing refrigerant line to hold pressure. If it holds pressure, flush and reconnect to the new system. Replace lines if there are leaks and cannot be repaired. Furnish the necessary refrigeration specialties required. Connect all existing voltage lines and low voltage wiring. Install new drain lines to the floor drain. Start the new unit, check the operation, and do any adjustments if needed.

Labor:

Bids must be prevailing wage.

MHA Contact Person: Maria Nino, Executive Assistant/Accounting Coordinator
1130 43rd Street
Moline, IL 61265
maria@molinehousing.com
Phone: 309-764-0847
Fax: 309-764-1069

MHA Executive Director: John Afoun
jfa@molinehousing.com
Phone: 309-277-0283

Maintenance Supervisor: Don Wales
don@molinehousing.com
Phone: 309-314-4273
Fax: 309-764-1819

Proposal Submittal
Return & Deadline: April 8, 2024
MHA Attn: Maria Nino
4141 11th Ave. A Moline, IL 61265